

- AWWA C509 RESILIENT SEATED GATE VALVE MAY BE SUBSTITUTED FOR STORMWATER VALVE PER ENGINEER'S APPROVAL.
- 2. CONSTRUCT FLOW RESTRICTOR TO ACCOMMODATE 8" FLANGE CONNECTION FOR VALVE. MAY USE 8" X OUTLET PIPE DIAMETER FLANGED REDUCER OR ACCEPTED EQUIVALENT.

CITY OF REDMOND, WASHINGTON

APPROVED BY: RON GRANT

REVISION DATE: MARCH 01, 2012

CITY ENGINEER





STANDARD DETAILS

STORMWATER VALVE

FILE NAME: SD611.DWG

DETAIL NUMBER: 611