

NOTES:

- 1. SEE STANDARD DETAILS 701A, 701B, 702, 703, AND 704A FOR ADDITIONAL DETAILS.
- 2. SEE STANDARD DETAIL 711 FOR ADDITIONAL INFORMATION ON BACKFLOW PREVENTORS (BFP).
- AN APPROVED BACKFLOW PREVENTOR IS REQUIRED FOR ALL FIRE SPRINKLER SYSTEMS EXCEPT APPROVED FLOW-THROUGH SYSTEMS. BFPS SHALL BE LOCATED DOWNSTREAM IN THE BUILDING OR ADJACENT TO THE FIRE SYSTEM METER BOX.

CITY OF REDMOND, WASHINGTON

APPROVED BY: RON GRANT

CITY ENGINEER







STANDARD DETAILS

RESIDENTIAL FIRE SPRINKLER DETAILS

FILE NAME: SD704.DWG DETA

DETAIL NUMBER: 704