

NOTES:

- 8 INCH PRV STATION SHOWN. 6 INCH PRV STATION IS IDENTICAL EXCEPT THE UPSTREAM AND DOWNSTREAM PIPING, FITTINGS, AND VALVES ARE 6 INCHES.
- 2. PAINT ALL EXPOSED PIPING AND FITTINGS WITHIN VAULT AND ABOVE GRADE.
- ALL VALVES INSIDE VAULT TO HAVE HAND WHEEL OPERATORS.
- SET COVER SLAB FLUSH WITH SIDEWALK OR CURB ELEVATION IF LOCATED IN LAWN AREA. SET COVER SLAB APPROXIMATELY 2 INCHES ABOVE FINISHED GRADE IF LOCATED IN LANDSCAPING AREA.

CITY OF REDMOND, WASHINGTON

APPROVED BY: RON GRANT

REVISION DATE: MARCH 01, 2010

CITY ENGINEER





STANDARD DETAILS

6" AND 8" PRV STATION SECTION

FILE NAME: SD709B.DWG DETAIL NUMBER: 709B