



PLAN
NTS

NOTES:

1. USE GATE VALVE SERVICE CONNECTION. SEE STANDARD DETAIL 701B.
2. FOR 5/8 INCH X 3/4 INCH METER SETTERS, MANIFOLD LENGTH BETWEEN SETTERS SHALL BE 10 INCHES. FOR 1 INCH METER SETTERS, MANIFOLD LENGTH BETWEEN SETTERS SHALL BE 10 INCHES.
3. FOR 5/8 INCH X 3/4 INCH METER SETTERS, MANIFOLD SIZE SHALL BE 3/4 INCH FROM BUSHING AT CROSS. FOR 1 INCH METER SETTERS, MANIFOLD SIZE SHALL BE 1 INCH FROM BUSHING AT CROSS.
4. FOR 5/8 INCH X 3/4 INCH METER SETTERS, USE 1- 17 INCH X 30 INCH METER BOX AS SHOWN. FOR 1 INCH METER SETTERS, USE INDIVIDUAL METER BOXES SIMILAR TO THE SINGLE SERVICE STANDARD DETAIL 703.
5. THE METER BOX SHALL BE CENTERED OVER THE SETTER ASSEMBLY AS SHOWN.

CITY OF REDMOND, WASHINGTON			STANDARD DETAILS	
APPROVED BY: RON GRANT CITY ENGINEER			TRIPLE SERVICE MANIFOLD	
REVISION DATE: MARCH 01, 2010			FILE NAME: SD703B.DWG	DETAIL NUMBER: 703B