

NOTES:

- 1. USE GATE VALVE SERVICE CONNECTION, SEE STANDARD DETAIL 701B.
- 2. FOR 5/8 INCH X 3/4 INCH METER SETTERS, 2 INCH MANIFOLD LENGTH BETWEEN SETTERS SHALL BE 30 INCHES. FOR 1 INCH METER SETTERS, 2 INCH MANIFOLD LENGTH BETWEEN SETTERS SHALL BE 24 INCHES.
- 3. FOR 5/8 INCH X 3/4 INCH METER SETTERS, MANIFOLD SIZE SHALL BE 3/4 INCH FROM BUSHING AT TEE. FOR 1 INCH METER SETTERS, MANIFOLD SIZE SHALL BE 1 INCH FROM BUSHING AT TEE.
- 4. FOR 5/8 INCH X 3/4 INCH METER SETTERS, MANIFOLD LENGTH BETWEEN SETTERS SHALL BE 18 INCHES. FOR 1 INCH METER SETTERS, MANIFOLD LENGTH BETWEEN SETTERS SHALL BE 18 INCHES.
- 5. FOR 5/8 INCH X 3/4 INCH METER SETTERS, USE 2- 17 INCH X 30 INCH METER BOXES AS SHOWN. FOR 1 INCH METER SETTERS, USE INDIVIDUAL METER BOXES SIMILAR TO THE SINGLE SERVICE STANDARD DETAIL 703.
- 6. THE METER BOXES SHALL BE CENTERED OVER THE METER SETTER ASSEMBLIES AS SHOWN.

CITY OF REDMOND, WASHINGTON

APPROVED BY: RON GRANT

REVISION DATE: MARCH 01, 2010

CITY ENGINEER





STANDARD DETAILS

QUADRUPLE SERVICE MANIFOLD

FILE NAME: SD703C.DWG DETAIL NUMBER: 703C