

- THE CONSTRUCTION DRAWINGS.
- 2. FOR 1 INCH COMBINATION VALVE, INSTALL 2 INCH X 1 INCH REDUCER BETWEEN GATE VALVE AND UNION.
- FILL METER BOX WITH SAWDUST AFTER TESTING AND INSPECTION.
- INSTALL STANDARD MARKER POST IDENTIFYING VALVE LOCATION (NOT SHOWN).
- SET METER BOX FLUSH WITH SIDEWALK OR CURB ELEVATION IF LOCATED IN LAWN AREA. SET METER BOX APPROXIMATELY 2 INCHES ABOVE FINISHED GRADE IF IN LANDSCAPED AREA.

CITY OF REDMOND, WASHINGTON

APPROVED BY: RON GRANT

CITY ENGINEER

REVISION DATE: MARCH 01, 2010





STANDARD DETAILS

COMBINATION AIR RELEASE AND **VACUUM VALVE ASSEMBLY**

FILE NAME: SD706.DWG

DETAIL NUMBER: 706