



**SECTION**  
NTS

NOTES:

1. SEE STANDARD DETAIL 701A FOR CONNECTION TO MAIN.
2. SET METER BOX FLUSH WITH SIDEWALK OR CURB ELEVATION IF LOCATED IN LAWN AREA. SET METER BOX APPROXIMATELY 2 INCHES ABOVE FINISHED GRADE IF IN LANDSCAPING AREA.
3. INSTALL STANDARD MARKER POST IDENTIFYING BLOW-OFF LOCATION. (NOT SHOWN)
4. ANY ADDITIONAL FITTINGS FROM THE GATE VALVE TO THE MAIN SHALL BE BRASS.

CITY OF REDMOND, WASHINGTON		 City of Redmond WASHINGTON	STANDARD DETAILS	
APPROVED BY: RON GRANT CITY ENGINEER			<b>BLOW-OFF ASSEMBLY</b>	
REVISION DATE: MARCH 01, 2010			FILE NAME: SD707.DWG	DETAIL NUMBER: <b>707</b>