



TYPICAL SECTION

## NOTES:

- MAXIMUM DISTANCE BETWEEN PIPE CLEANOUTS OR YARD DRAINS SHALL BE 75 FEET.
- FOR NEW CONSTRUCTION, LOCATE YARD DRAINS NEAR PROPERTY LINES. YARD DRAINS MAY BE SHARED BY TWO PROPERTIES.
- 3. FOR RETROFITS, LOCATE YARD DRAINS AND LIMITS OF SIDEWALK REPLACEMENT AS DIRECTED BY INSPECTOR. REMOVE SIDEWALK TO EXISTING EXPANSION JOINTS.
- 4. PROTECT ADJACENT WALLS, VEGETATION, DRIVEWAYS, AND OTHER FEATURES.

CITY OF REDMOND, WASHINGTON

NTS

APPROVED BY: RON GRANT

CITY ENGINEER

REVISION DATE: MARCH 01, 2011





STANDARD DETAILS

SIDEWALK
UNDERDRAIN SYSTEM

FILE NAME: SD630.DWG DETAIL N

DETAIL NUMBER: 630