

NOTES:

- 1. ELECTRICAL PERMIT REQUIRED IF WATER PUMP IS TO BE INSTALLED.
- 2. ENGINEERING DESIGN IS REQUIRED FOR CISTERNS GREATER THAN 60 GALLONS OR FOR BELOW GROUND SYSTEMS.
- 3. THERE SHALL BE NO CONNECTION BETWEEN RAIN HARVESTING SYSTEM AND POTABLE WATER SUPPLY.
- 4. THE OWNER IS RESPONSIBLE FOR ENSURING SAFE DISCHARGE OF OVERFLOWS WITHOUT CONCENTRATING FLOWS TO CAUSE EROSION OR FLOODING.

CITY OF REDMOND, WASHINGTON

APPROVED BY: RON GRANT

REVISION DATE: MARCH 01, 2012

CITY ENGINEER





STANDARD DETAILS

ROOF RAIN HARVESTING

FILE NAME: SD650 DWG

DETAIL NUMBER: 650