



THE CITY OF REDMOND  
FIRE DEPARTMENT - PREVENTION DIVISION  
**Redmond Fire Department Standards  
Administrative Ruling / Interpretation**



**Code Section: 9.4.11**

**Code Edition: 2000**

**Title: Clarification of responsibility for elements of Central Station Service**

**Date: November 17, 2000**

**Statement of Need:**

Current wording can be read to mean that only Central Stations can provide any of the elements of Central Station Service. This is contrary to the intent and will be reworded in subsequent editions.

**Ruling/Interpretation:**

This section states in part: "Central Stations shall provide alarm and supervisory services plus maintenance, inspection, testing, and runner service in conformance with these standards." Within the context, this sentence refers to the entire package of elements that constitute central station service and which are required in accordance with the sections that follow. In the remainder of the section, allowable methods are specifically identified and are in fact identical with the options allowed by NFPA 72.

The sentence quoted above shall be revised in the next addition to read as follows: "Central Station alarm and supervisory services plus maintenance, inspection, testing, and runner service shall be provided in conformance with these standards."

---

Robert Lovett  
Fire Marshal