



**Scott Sherrow P.E.** | Senior Principal Engineer  
11255 Kirkland Way | Suite 300 | Kirkland, WA 98033  
p. 425.827.2014 | f. 425.827.5043  
[www.PACEENGRS.com](http://www.PACEENGRS.com)

**From:** King Chin [mailto:kchin@geoengineers.com]  
**Sent:** Thursday, March 09, 2017 2:30 PM  
**To:** Scott Sherrow <scotts@paceengrs.com>  
**Subject:** RE: Washington Cathedral Site

Hi, Scott. Based on the geologic map, the Washington Cathedral site is underlain by glacial till and transitional bed, both material is practically impermeable and is unfavorable for an infiltration facilities.

Thanks,

king

**King H. Chin, PE**  
**Principal/PBE-RA Group Leader | GeoEngineers, Inc.**  
**Telephone:** 425.861.6098  
**Fax:** 425.861.6050  
**Mobile:** 206.979.5807  
**Email:** [kchin@geoengineers.com](mailto:kchin@geoengineers.com)

8410 154th Avenue NE  
Redmond, WA 98052  
[www.geoengineers.com](http://www.geoengineers.com)

---

**Disclaimer:** Any electronic form, facsimile or hard copy of the original document (email, text, table, and/or figure), if provided, and any attachments are only a copy of the original document. The original document is stored by GeoEngineers, Inc. and will serve as the official document of record.