



Residential Sprinklers Are Required When:*

RMC 15.06.016 and CDG20F 10.50.090(3)

Residential Sprinklers are required for any newly constructed one or two family residence or for an addition or modification to an existing one or two family residence where one or more of the following apply:

- 1. An addition to an existing one or two family dwelling results in square footage greater than 3600 square feet*.
- 2. An addition to an existing one or two family dwelling in a low flow area results in inadequate fire flow (RFDS 3.1.1.11).
- 3. The access grade (on or off site) is greater than 10% (RFDS 2.1.1.5).
- 4. The access roadway is less than 14 feet wide or greater than 150 feet long (RFDS 2.1.1.6).
- 5. The distance of the building to the nearest hydrant is greater than 300 feet (RMC 15.06.013, Amendment 30).
- 6. The total construction costs on all building permits within a three year period exceed the King County assessed value of the structure at the beginning of the three year period (RMC 15.06.024).
- 7. There will be a 100% or greater increase in gross square footage (RMC 15.06.024).
- 8. A non-conforming structure has been destroyed, damaged or incurred a loss equal to or greater than 60 percent of its King County assessed value (RMC 15.06.024)?

^{*}Structures separated by 10 feet or less shall be considered as one building for the purposes of the above questions (RFDS 3.1.1.0).

^{*}The Fire Marshal may allow other forms of mitigation to deal with special or unique circumstances