



FACP and Sprinkler Zone Map Requirements:

A fire alarm/sprinkler zone map shall be provided next to the fire alarm control panel. These map(s) shall show what areas of the building are covered by the system(s) installed. Maps shall be accurate, legible and easily understood. They shall be laminated and permanently attached to the wall in the FACP/Riser room. When a building or system is modified, it is the responsibility of the contractor who made modifications to the system(s) to update these maps.

The maps shall include the following minimum items:

- 1. Building layout
- 2. Stairwell identification
- 3. Location of fire-rated walls and their ratings
- 4. Knox Box location(s)
- 5. Adjacent streets, with designators
- 6. North arrow
- 7. Legend of symbols
- 8. Date drawing was created
- 9. Location of all sprinkler zones
- 10. FACP
- 11. NAC panels
- 12. Standpipe outlets
- 13. Sprinkler control valves (Including PIV's and FDC's)
- 14. Water-flow alarm devices
- 15. Range hood suppression systems
- 16. Clean agent systems
- 17. Vesda systems
- 18. Addressable fire alarm system device ID's and/or area descriptions
- 19. Inspector's test valve(s)
- 20. Auxiliary drain(s)